1. 18" OR GREATER BUTTERFLY VALVE FLxFL OPERATOR ON OPPOSITE SIDE OF BY-PASS CENTER BUTTERFLY VALVE BETWEEN TEE'S.
2. FLxMJ ADAPTER WITH MEGA LUG FOLLOWERS.
3. DI PIPE, LENGTH AS NEEDED.
4. X"x6" TEE MJxFL WITH MEGA LUG FOLLOWERS.
5. 3'-6"Ø SPOOL FLxMJ.
6. 6" 90° BEND FLxFL.
7. 6" FL x PE SPOOL.
8. 6" FLxMJ ADAPTER WITH MEGA LUG FOLLOWERS.
9. 6" GATE VALVE FLxFL.
10. THRUST BLOCKING.

NOTE: THIS PLAN IS NOT A LEGAL ENGINEERING DOCUMENT BUT AN ELECTRONIC DUPLICATE. THE ORIGINAL, SIGNED BY THE ENGINEER AND APPROVED FOR PUBLICATION IS KEPT ON FILE AT THE CITY OF KENT. A COPY MAY BE OBTAINED UPON REQUEST.

KENT WASHINGTON

CITY OF KENT
ENGINEERING DEPARTMENT

18" OR GREATER VALVE BY-PASS

DESIGNED DMW	SCALE NONE	STANDARD PLAN
DRAWN BB		
CHECKED	DATE	3-8
APPROVED	ENGINEER	